



A CSW Industrials Company

GENERAL CERTIFICATE OF COMPLIANCE

DESCRIPTION:

METACAULK® FIRESTOPPING PRODUCTS

METACAULK® MC 150+ FIRESTOP SEALANT
METACAULK® 350i FIRESTOP SEALANT
METACAULK® 835+ SILICONE SEALANT
METACAULK® 835+ SILICONE SPRAY
METACAULK® 950 FIRESTOP SEALANT
METACAULK® 1000 FIRESTOP SEALANT
METACAULK® 1200
METACAULK® BLAZESEAL™
METACAULK® BOX GUARD™
METACAULK® COMPOSITE SHEET
METACAULK® COVER GUARD™
METACAULK® FIRE-RATED MORTAR
METACAULK® FIRESTOP PILLOW
METACAULK® INDUSTRIAL CABLE COATING
METACAULK® INTUMESCENT SLEEVE
METACAULK® JOINT STRIP
METACAULK® PIPE COLLAR
METACAULK® CID
METACAULK® PUTTY STICK & PUTTY PAD
METACAULK® WRAP STRIP
FLAMESAFE® BAGS
FLAMESAFE® FS 900+ SEALANT
RECTORSEAL® BLAZE FOAM™
RECTORSEAL® SMOKE AND ACOUSTIC SEALANT

THESE PRODUCTS ARE TESTED ACCORDING TO ONE OR MORE OF THE FOLLOWING STANDARDS:

U.L. 263 - FIRE TESTS OF BUILDING CONSTRUCTION AND MATERIALS
U.L. 1479 - FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
U.L. 2079 - TESTS FOR FIRE RESISTANCE OF BUILDING JOINT SYSTEMS
ASTM E-84 (UL 723) - SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS
ASTM E-814 - FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
ASTM E-2307 - METHOD FOR DETERMINING FIRE RESISTANCE OF PERIMETER FIRE BARRIERS
IEEE 1202 - FLAME-PROPAGATION TESTING OF WIRE & CABLE



A CSW Industrials Company

ALL PRODUCTS CONTAIN NO ASBESTOS OR PCB'S AND ARE CONSIDERED V.O.C. COMPLIANT.

EVA ACKERMAN PH.D
VICE PRESIDENT OF RESEARCH & TECHNOLOGY

TERRY GOSSETT
TECHNICAL SERVICES

SUBSCRIBED AND SWORN TO BEFORE ME THIS 22nd DAY OF January 2020.

MELISSA SCHOENBERG
NOTARY IN AND FOR THE STATE OF TEXAS
COUNTY OF HARRIS
MY COMMISSION EXPIRES: OCTOBER 25, 2023

